

Donald Kasprzak
Mayor
41 City Hall Place
Plattsburgh, NY 12901

Willard J. Todd
Chief Plant Operator
549 Route 3
Plattsburgh, NY 12901

April 27, 2009

**Annual Drinking Water Quality Report for 2008
City of Plattsburgh Water System
Plattsburgh, New York
(Public Water Supply ID#0900217)**

INTRODUCTION

To comply with State and Federal regulations, we annually issue a report describing the quality of your drinking water. The purpose of this report is to enhance your understanding of drinking water and increase awareness for the need to protect our drinking water sources. This report provides and overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards. If you have any questions about this report or concerns about your drinking water, please contact Willard Todd, Chief Plant Operator at (518) 563-1188 or Jonathan P. Ruff, P.E. at 518-563-7731. The Mayor and Members of the Common Council hold meetings every Thursday evening at 6:00 p.m. in the Common Council Chambers at City Hall.

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: pesticides, herbicides, microbial, organic, inorganic, chemical and radioactive. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations also establish limits for contaminants in bottled water which must provide the same protection for the public's health.

The City of Plattsburgh utilizes three upland gravity surface water sources (Mead Reservoir, West Brook Reservoirs and the Saranac River) to supply drinking water to the City of Plattsburgh users. The two reservoirs are located approximately five miles west of the City of Plattsburgh, located near the intersection of Rand Hill Road and Route 374. Water taken from the reservoirs is piped to the City's water filtration plant located west of the city limits on New York State Route 3, Cornelia Street. Water can also be withdrawn from the Saranac River located on the Kent Falls Road in Cadyville and piped into the West Brook Reservoir. At the water filtration plant, the water has chlorination, sedimentation, filtration, and fluoridation treatments and is stored in reservoirs. After treatment, the water is distributed to the City of Plattsburgh users. The city water system did not experience any water source restriction during 2008.

FACTS AND FIGURES

Our water system serves approximately 26,174 individuals (18,816 population in 2000 census plus 6,358 SUNY enrollment) through 5,357 water meters. The cost for a customer using 6000 gallons per month is about \$321/year. The amount of water treated at the water filtration plant in 2008 was 934,303,000 gallons. The total amount of water delivered to customers was recorded at 852,545,000 gallons. This leaves an unaccounted total of 81,758,000 gallons. We believe this is due to the water used to flush hydrants, backwash filters, fight fires and leakage (water main breaks). Also, the water meters at the Water Filtration Plant are designed to measure high flows and are not as accurate with the lower flows. There may also be some inaccuracies with meters that record the water used by customers.

SOURCE WATER ASSESSMENT REPORT SUMMARY

The NYS DOH has completed source water assessments for this system, based on available information. Possible and actual threats to these drinking water sources were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move to the source. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section “**Are There Contaminants in Our Drinking Water**” for a list of detected contaminants. The source water assessments provide resource managers with additional information for protecting source waters in the future.

SOURCE: Mead Reservoir

This assessment found an elevated susceptibility to contamination for this source of drinking water prior to treatment. The amount of agricultural lands in the assessment area results in elevated potential for protozoa and pesticide contamination. No permitted discharges are found in the assessment area. There is also considerable susceptibility associated with other discrete contaminant sources, and these facility types including mines, which may generate turbidity. Finally, it should be noted that hydrologic characteristics (e.g. basin shape and flushing rates) generally make reservoirs highly sensitive to existing and new sources of phosphorus and microbial contamination.

SOURCE: West Brook Reservoir

This assessment found a moderate susceptibility to contamination for this source of drinking water prior to treatment. Land cover and its associated activities within the assessment area do not increase the potential for contamination. No permitted discharges are found in the assessment area. There is also noteworthy contamination susceptibility associated with other discrete contamination sources, and these facility types including , mines which may generate turbidity. Finally, it should be noted that hydrologic characteristics (e.g. basin shape and flushing rates) generally make reservoirs highly sensitive to existing and new sources of phosphorus and microbial contamination.

SOURCE: Saranac River

This assessment found a moderate susceptibility to contamination for this source of drinking water. Land cover and associated activities within the assessment area do not increase the potential for contamination. While there are some facilities present, permitted discharges are not likely represented as an important threat to water source quality based on their density in the assessment area. However, it appears that the total amount of wastewater discharged to surface water in this assessment area may be high enough to further raise the potential for contamination (particularly for protozoa). There are no noteworthy contamination threats associated with other discrete contaminant sources. Finally, it should be noted that relatively high flow velocities make river drinking water supplies highly sensitive to existing and sources of microbial contamination. Please note that, while the source water assessment, rate reservoirs and rivers as highly sensitive to microbial contamination, our water is disinfected to ensure that the finished water delivered into your home meets the New York State drinking water standards for microbial contamination. A copy of this assessment, including a map of the assessment area, can be obtained by contacting us, as noted above.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulation require, we routinely test your drinking water for numerous contaminants. During calendar year 2008 we tested for Inorganic Compounds, Nitrate, Volatile Organic Compounds, Total Trihalomethanes, Haloacetic Acids and Synthetic Organic Compounds. In addition, we tested the water for coliform bacteria 20 times each month and turbidity continuously. The table presented on the following page depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled water, might be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Calling the EPA’s Safe Drinking Water Hot line (800-426-4791) or the Clinton County Health Department at (518) 565-4870 can obtain more information about contaminants and potential health effects.

Table of Detected Contaminants							
Contaminant	Violation Y/N	Date of Sample	Level Detected	Unit Measure- Ment	MCLG	Regulatory Limit (MCL, TT or AL)	Likely source of Contamination
Turbidity (1)	No	2008	.01 TO .21	NTU	n/a	95% of samples<1.0 NTU (TT)	Soil runoff
Inorganic Contaminants							
Barium	No	02/20/08	0 .0153	mg/L	2	2(MCL)	Erosion of natural deposits.
Copper (2)	No	6/07 to 9/07	90 th =0.26 Range~ ND to 1.1	mg/l	1.3	1.3 (AL)	Corrosion of household plumbing systems.
Fluoride (4)	No	monthly	Average 0.92	mg/L	n/a	2.2 (MCL)	Erosion of natural deposits.
Nitrate	No	02/20/08	0.49	mg/L	n/a	10 (MCL)	Runoff from fertilizer use; leaching from septic tanks, sewage, erosion of natural deposits.
Lead (3)	No0	6/07 to 9/07	90 th =0.006 Range~ ND to .0193	mg/L	0	.015 (MCL)	Corrosion of household plumbing systems.
Sodium (5)	No	02/20/08	12.1	mg/L	n/a	See note (5)	Naturally occurring, road salt.
Chloride	No	2/20//08	18.2	mg/L	n/a	250 (MCL)	Naturally occurring or road salt.
(Total trihalomethanes) (TTHMs) (6)	No	Quarterly	Average= 68.45 Range= 29-89	ug/L	0	80	Byproduct of drinking water chlorination
(Total Haloacetic Acids) (HAA 5'S) (6)	No	Quarterly	Average= 53.03 Range=36-74	ug/L	n/a	60	Byproduct of drinking water chlorination
Radium 226 (7)	No	3 Quarters In 2005	Average =0.013	pCi/l	N/A	See note (7)	Erosion of natural deposits
Radium 228 (7)	No	3 Quarters In 2005	Average=0.9	pCi/l	N/A	See note (7)	Erosion of natural deposits
Sulfate	No	2/20/08	8.2	mg/l	N/A	MCL=250	Naturally occurring
Chromium	No	2/20/08	2.9	mg/l	100	MCL=100	Discharge from pulp mills and erosion of natural deposits
Nickel	No	2/20/08	0.008	mg/l	N/A	MCL=0.1	Naturally occurring

STAGE 2 DBP SAMPLING: (LRAA = Locational Running Average)

<u>Location</u>	<u>THM LRAA ug/l</u>	<u>HAA5 LRAA ug/l</u>
West Meter Pit	51.8	39.8
Stewarts	56.7	50.3
CVPH	54.0	42.2
McDonalds	57.0	44.9
South Side		
Grocery	59.8	44.1
WPCP	59.8	43.8
Library	53.2	43.4
		43
SUNY Police	56.9	.5

Notes:

- (1)-Turbidity is measure of the cloudiness of the water. We test it because it is good indicator of the effectiveness of our filtration system. In 2008, our highest turbidity measured 0.21 NTU occurred on March 14 2008. State regulations require the turbidity must not exceed 5 NTU and that 95% of the turbidity samples collected must measure below 1.0 NTU. All of the measurements collected in the 2008 were below 1.0 NTU.
- (2)-The level presented represents the 90th percentile of the 30 sites tested. A percentile is a value on the scale of 100 that indicated the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 30 samples were collected at your water system and the 90th percentile value for copper was 0.26 mg/l. The action level for copper was not exceeded at any of the sites tested in 2007.
- (3) The level presented represents the 90th percentile of the 30 sites tested. In this case, 30 samples were collected at your water system and the 90th percentile value for lead was 6 ug/l. The action level for lead was exceeded at one of the sites tested in 2007.
- (4) We sample for Fluoride monthly. The level presented represents the average of all monthly samples.
- (5)-Water containing more than 20 mg/L of sodium should not be used for drinking by people on very restricted sodium diets. Water containing more than 270 mg/L of sodium should not be used for drinking by people on moderately restricted sodium diets.
- (6)-One sample of water was collected each quarter and analyzed for TTHMs and HAA5s. The levels presented are the average of the four samples collected.
- (7) For Radium 226 and Radium 228 COMBINED the MCL=5 pci/l.

DEFINITIONS:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

LRAA- Locational Running Annual Average

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no MCL violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

The City of Plattsburgh water system is one of many systems in New York State that adds a low level of fluoride to drinking water in order to provide consumer dental health protection. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at levels that range from 0.8 to 1.2 mg/l (parts per million). Our fluoride addition facility is designed and operated to meet this optimal range.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

During 2008, the City of Plattsburgh Water System was in compliance with applicable state drinking water regulations, with the following exceptions:

- Testing for Synthetic Organic Contaminants was supposed to be conducted by June 30, 2008. The testing was not performed until July 16, 2008. We are happy to report that the results met the required water quality standards.
- The City of Plattsburgh submitted an updated Emergency Response Plan by the required January 1, 2008 date. The plan was subsequently approved by NYSDOH but some minor modifications were also requested. The modifications were not submitted by the requested July 1, 2008 date. This has been addressed.

Also, there were approximately 18 Boil Water Advisories issued. Most, if not all, of these were issued as a precautionary measure due to system maintenance or repair.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immune-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

Saving water saves energy and some of the costs associated with both of the necessities of life:

Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential fire fighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water our household is using, and by looking for ways to use less water whenever you can. It is not hard to conserve water. Conservation tips include:

Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity. Turn off the tap when brushing your teeth.

Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 of water gallons per year.

Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.

Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes, if it advances, you have a leak.

SYSTEM IMPROVEMENTS AND OTHER PROGRAMS:

- The design of the new finished water storage tank was completed and put out for bids (construction began in March 2009).
- A structural evaluation of the 1956 filter building was performed in 2008 and necessary repairs undertaken.
- The dams at the City reservoirs were inspected and evaluated for compliance with existing and proposed regulations. The dams were found to be stable, in reasonable good condition, and well maintained. A program for performing maintenance and upgrades is being developed.
- Emergency Action Plans for the City dams were updated as necessary.

CLOSING: Thank you for allowing us to continue to provide you with quality drinking water. We ask that all our customers help us protect our water sources, which are the heart of our community and our way of life. Please call our office if you have questions.